



Pol. Ind. Lasao. Area Arandi, n°5
20730 AZPEITIA (Guipúzcoa)
Tel. 943 816800 – Fax: 943 816074
Email: cidemco@cidemco.es
<http://www.codemco.es>

REFERENCE NUMBER FOR REPORT: 16339-2
Page 1 of 1

Date of Issue: 23rd October, 2008
Date of Reception: 25th June, 2008

CLIENT: DRIZORO, S.A.

PETITIONER: Mr. FRANCISCO RODRIGUEZ

ADDRESS: C/ Primavera 50-52
28850 TORREJÓN DE ARDOZ

REFERENCE:
DELIVERED MATERIAL: "MAXSEAL SUPER"
25 KG OF WATERPROOFING MORTAR "MAXSEAL SUPER"

REFERENCE	STANDARD	TITLE	SPECIMEN	BOND STRENGTH (MPa)
"MAXSEAL SUPER"	UNE-EN 1542:2000	Measurement of bond strength by pull-off	1	1,71
			2	1,58
			3	1,53
			Average	1,61
			Standard Deviation	0,09



(Illegible signature and laboratory stamp)
Mr. Javier GARCÍA JACA
Director of Material Department