



Pol. Ind. Lasao. Area Arandi, n°5
20730 AZPEITIA (Guipúzcoa)
Tel. 943 816800 – Fax: 943 816074
Email: cidemco@cidemco.es
<http://www.codemco.es>

REFERENCE NUMBER FOR REPORT: 16337-5
Page 1 of 1

Date of Issue: 23rd October, 2008
Date of Reception: 25th June, 2008

CLIENT: DRIZORO, S.A.

PETITIONER: Mr. FRANCISCO RODRIGUEZ

ADDRESS: C/ Primavera 50-52
28850 TORREJÓN DE ARDOZ

REFERENCE:
DELIVERED MATERIAL: “MAXSEAL”
25 KG OF WATERPROOFING MORTAR & 2 PLASTIC JERRYCANS OF
LIQUID ADMIXTURE “MAXCRYL” (5 LITERS PER JERRYCAN)

REFERENCE	STANDARD	TITLE	RESULT
“MAXSEAL”	UNE-EN ISO 7783-1:2000 UNE-EN ISO 7783-2:1999	Determination of the water vapour transmission rate (permeability)	$V = 78,94 \text{ g/m}^2 \cdot \text{day}$ $S_D = 0,27 \text{ m}$



(Illegible signature and Stamp)
Mr. Javier GARCÍA JACA
Director of Material Department